

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-0694:198

Page 1 of 1

**CATEGORY:** Audible Devices

**LISTEE:** Fire Control Instruments, 301 2<sup>nd</sup> Avenue, Waltham, MA 02451-1133  
Contact: Anthony J. Shalna (781) 487-0088

**DESIGN:** Model HA electronic horn. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as an electronic horn for use with separately listed compatible fire alarm control units.  
For wall mount and indoor use only.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**XLF:** 7135-0553:001

09-16-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**MAY 23, 2001**

*Listing Expires **June 30, 2002***

Authorized By:

**BEN HO**, Supervising Deputy  
Program Manager